

CATALOG #		TYPE
JOB NAME	WATTAGE	VOLTAGE

8" 150 WATT MAXIMUM 1 A21

RR00832

Uniform Illumination for MRI: Non-Ferrous Luminaire



Non-Magnetic Lamp/Socket

- · Designed for:
 - 150 watt (max.) A21 frosted lamp (by others).
- Dimmable (controls by others).
- For operation on D.C. circuits.
- · Glazed porcelain medium base horizontal socket. Nickel plated brass screw shell. Silicone leads.

Reflector

· Specular Alzak® aluminum.

Trim Assembly

- · Smooth white seamless tapered aluminum selfflanged flare trim.
- Prismatic low brightness, spread distribution C#73 lens standard.
- Optional lenses and flat trim available, see Options.
- · Non-ferrous torsion springs retain snug fit to ceiling.

Housing

- Cool. Acrylic enameled 100% aluminum.
- Rustproof: Exceeds 1000 hour ASTM 5% salt spray test.

- Dissipates heat across entire surface area.
- Entire luminaire visible and serviceable from below through removable reflector.
- Built-in plaster frame. Also see Option -79.

Outlet Box

- Prewired. 100% aluminum. UL listed.
- Accessible. 1/2" and 3/4" knockouts.

Installation

- · Lightweight. Recesses in any ceiling type.
- 27" aluminum hanger bars supplied (2).
- Fully adjustable universal non-magnetic mounting brackets supplied (2).

UL, C-UL (Canada) Listings


- Wet, damp or dry locations, covered ceilings.
- Through-branch circuit conductors (up to 6 #12). Supply wire rating: 90°C.

Three Year Limited Warranty

· Complete standard fixture.

Thermal Protection (Per Current NEC)


 Thermal protector included which provides automatic cut-off if rated temperature is exceeded. (Insulation related)





Recessed Round Regressed Lensed Shallow Plenum **MRI**


NOT RESTRICTED TO END-OF-RUN USE

Performance at a Glance









Dia. (in ft.) shown is where FC value is half the FC at nadir.

Cone of Light Key Distance from fixture Footcandles at nadir (0°)

Circle of light at 50% of FC

THE KIRLIN COMPANY

3401 EAST JEFFERSON AVENUE • DETROIT, MICHIGAN 48207-4232 (313) 259-6400 • Fax: (313) 259-9409 or (313) 259-3121 • www.kirlinlighting.com

HEALTHCARE FACILITY & PATIENT LIGHTING

MAXIMUM WATTAGE

1 A21 150

CATALOG NUMBER


RR00832



Detailed Photometry - Installed Fixture

Photometry from I.T.L., Boulder, CO

RR00832 (150 Watt)



EFFICIENCY: 52.6%

CANDLEPOWER DISTRIBUTION							
0.0		45.0	45.0 90.0		180.0		
0	1044	1044	1044	1044	1044		
5	1021	1031	1017	1012	1004		
15	923	966	937	861	810		
25	801	921	877	754	652		
35	581	599	588	488	434		
45	282	297	291	252	222		
55	122	142	138	127	109		
65	53	60	59	61	62		
75	13	18	21	20	19		
85	2	6	6	6	6		
90	0	0	0	0	0		

	COEFFICIENTS OF UTILIZATION							
F	RF	20						
F	RC	80				50		
F	RW	70	50	30	10	50	30	10
	1	59	57	55	54	54	53	51
	2	55	52	49	47	49	47	45
	3	51	47	44	41	45	42	40
	4	48	43	39	37	41	38	36
	5	45	39	36	33	38	35	32
	6	42	36	32	30	35	32	29
	7	39	34	30	27	32	29	27
	8	37	31	27	25	30	27	25
	9	35	29	25	23	28	25	23
-	10	33	27	23	21	26	23	21

ITL TEST #46994

Options

- -18 Anopal flat glass. Not enameled. Diffusing.
- -20 Louver, aluminum, egg-crate. 1/2" cube. White.
- -32 Trim extender. Broadens trim flange O.D. by 1" to cover larger ceiling opening.
- -44 Black OptiGroove regressed trim with white flange instead; with C#73 lens or add optional lens.
- -45 Gasket between trim flange and ceiling.
- -46 Gasket between lens and trim.
- -79 Extension collar for up to 2" thick ceiling.
- -94 Custom color flare trim. Consult factory.
- -99 Special modification. Consult factory.
- FR Fresnel lens instead.
- -FT Flat white trim instead. Standard with prismatic flat glass, or add Option -18, -20 or -FR.
- -TC Teflon safety coating for specified lens. Consult factory.

SUBMITTAL DATA

APPROVAL STAMP

JOB NAME

TYPE

WATTAGE VOLTAGE

CATALOG NUMBER

LIMITED WORKANING A CAGE METAL TOCED KIRL IN FIGT MESS AFE WARRANTIED FREECTS IN WORKANISHIP OR MATERIAL PIGE AND THATE YEARS FROM THE YEARS AFE WARRANTIED FROM E.C. IN CORNAL U.S. Examples of project so this use or when of this purpose of all other proper of the buyer in the second and the second of purpose and detective future at the offices of manufacture repairs on the purpose of all other properties of the purpose of all other properties of the purpose of all other purposes of all other purposes of a purpose of a purpose