


CATALOG # TYPF JOB NAME WATTAGE **VOLTAGE**

> 12" 32 WATT MAXIMUM 2 Triple

VRR-10016

Vandal Resistant "IP65 Rated" Sealed & Gasketed Two Lamp Design



Specifications

 Designed for two 4-pin triple tube amalgam or quad compact fluorescent lamps: 32/26W triple or 26W guad.

Ballast: Multi-Wattage/Voltage

- · Installed electronic high power factor, thermally protected. For lower wattages: Option -43.
- 120-277 multi-volt; 50-60 Hz. THD <10%.
- ClickQuick connectors for easy service.
- Single circuit wiring or see Option -84.
- Cold weather -22°F (-30°C).
- End of lamp life protection circuit. RFI filter.
- Internally fused. Also see Options -FS, -FD.

Reflector

• Specular Alzak® aluminum.

Trim / Lens Assembly

- · Vandal resistant smooth white seamless tapered aluminum self-flanged flare trim or see Option -OG.
- Flush center pin tamperproof hex screws (2) with captive nuts secure trim to housing.
- 3/16" prismatic high strength acrylic lens

above 1/4" clear polycarbonate. Continuous ring secures lens to trim.

Tamperproof tool included.

5X Sealed and Gasketed

• (1) Silicone seal between trim and lens seals lens to trim, (2) closed cell gasketing between trim and housing flange seals trim to housing, (3) closed cell gasketing on trim flange seals flange to ceiling (4) closed cell gasketing on bottom pan seals housing to ceiling and (5) neoprene O-rings on stainless steel fasteners seal fasteners to trim.

Aluminum Housing

- Acrylic enameled, Rustproof; Exceeds 1000 hour ASTM 5% salt spray test.
- · Built-in plaster frame surrounded by closed cell silicone gasketing seals housing to
- Lightweight: Minimizes ceiling load.
- Cool operation: Extends component life.
- Entire luminaire serviced through aperture.
- Air Tight design. Meets / exceeds ASTM E283 restricted airflow of 2 CFM maximum.





Outlet Box

• Prewired 14 GA (NEC) galvanized steel, UL listed. 1/2" and 3/4" knockouts.

Installation

- 27" galvanized hanger bars with adjustable mounting brackets (2) supplied.
- · Recesses indoor or outdoor in covered locations

UL, C-UL (Canada) Listings


- · Wet, damp or dry locations, covered ceilings.
- Through-branch conductors (6#12 AWG

Three Year Limited Warranty


• Complete standard fixture and ballast.

Performance at a Glance

VRR-10016




Option -OG Also Shown



Ceiling Cut-out 101/2" Dia.

VRR-10016 (2 Triple 32W)



6	29.1		7.2
8	16.4		9.6
10	10.5	1	1.9
12	7.3	1.	4.3
14	5.4	1	6.7
16	4.1	1	9.1
==	45°	SC SC SC	1.2
LER=28.1	AEC	C=\$8	3.55

Cone of Light Key

Distance from fixture Footcandles at nadir (0°) Circle of light at 50% of FC

Dia. (in ft.) shown is where FC value is half the FC at nadir.

THE KIRLIN COMPANY

3401 EAST JEFFERSON AVENUE • DETROIT, MICHIGAN 48207-4232 (313) 259-6400 • Fax: (313) 259-9409 OR (313) 259-3121 • www.kirlinlighting.com

ENERGY EFFICIENT VANDAL RESISTANT & MAXIMUM SECURITY LIGHTING

MAXIMUM WATTAGE

2 Triple 32

CATALOG NUMBER


VRR-10016



Detailed Photometry - Installed Fixture

Photometry from I.T.L., Boulder, CO

VRR-10016 (2 Triple 32)



EFFICIENCY: 44.4%

CANDLEPOWER DISTRIBUTION							
0.0		22.5 45.0		67.5	90.0		
0	1049	1049	1049	1049	1049		
5	1038	1041	1046	1050	1051		
15	970	983	1010	1035	1045		
25	854	872	918	962	980		
35	687	708	757	800	814		
45	489	507	546	578	590		
55	280	290	312	333	342		
65	117	120	130	138	140		
75	23	24	25	26	27		
85	0	0	0	0	0		
90	0	0	0	0	0		

COEFFICIENTS OF UTILIZATION							
RF	20						
RC	80			50			
RW	70	50	30	10	50	30	10
1	49	48	46	45	45	44	43
2	46	43	40	38	41	39	37
3	42	38	35	33	37	34	32
4	39	35	31	29	33	30	28
5	36	31	28	25	30	27	25
6	34	29	25	22	27	24	22
7	32	26	23	20	25	22	20
8	29	24	21	18	23	20	18
9	28	22	19	16	21	18	16
10	26	20	17	15	20	17	15

ITL TEST #59120 *LER=28.1 •AEC=\$8.55

* LER = Luminaire Efficiency Rating

LER = <u>Luminaire Effic. x Total Lamp Lumens x Ballast Factor</u> Input Watts AEC = Annual Energy Cost per 1000 lumens (based on 3000 hours use @ \$0.08 KWH).

Options

Ballast, Wattage and Voltage

- -39 Installed electronic dimming ballast. Indoor use. 10°C (50°F) minimum start. Specify wattage, voltage and brand.
- Lower wattage: for 4-pin 18W triple or 18-13W quad. Specify wattage.
- -84 Wired for two circuits. Also see -FD.
- -97 Specify other voltage. Consult factory.
- -98 347 volt, 50/60 Hz. input. Consult factory.

Emergency Ballast - Specify Voltage¹

Internal (factory installed) ballast, test switch and indicator light. Suitable for damp locations from 0° to 50°C (32° to 122°F) or with Cold Weather version (see -CE) -20° to 55°C (-4° to 131°F).

- -73 Internal EM ballast. Specify voltage.
- -CE Internal cold weather (-20° to 55°C) EM ballast. Specify voltage.
- -HE¹ Internal higher lumen (up to 1250) EM ballast. 13-32W only. Specify voltage.

Lenses and Trims

- -94 Custom color/finish. Specify. Consult factory.
- -CF High temperature color filter. Specify color.
- -OG Black OptiGroove flare trim. (CP x .95)
- -UV UV filter. Consult factory.

Other

- -99 Special modification. Consult factory.
- -FD Two additional in-line fuses. One per ballast.
 Use with Option -84. Not available with Option -98(347V).
- FS Additional in-line fuse. Not available with Option -98(347V).
- -LE With 4-pin electronic lamps. 3500°K standard. 82 CRI and 12,000 hour life. Specify wattage, style and color temperature.

¹ Visit www.kirlinlighting.com for most current performance/specifications.

SUBMITTAL DATA

APPROVAL STAMP

JOB NAME

TYPE

WATTAGE VOLTAGE

CATALOG NUMBER

BULLETIN 07VR

LIMITED WARRANTY: CATAL OGED KIRLIN FIXTURES ARE WARRANTIED FREE OF DEFECTS IN WORKWAISHIP OR WATERAL FOR THREE YEARS FROM DATE of PURPA-BASE, INSTALLED TO N.E.G.; IN NORMAL USE. Manadequer at its option will replace or repair such fature or replace of proceed of procedule of purchase and defective fature at the offices of insulatativer within these years of original signment, basilish of manadequer is limited to the burst all not be able to purchase and defective fature at the offices of insulatativer within the years of original signment, basilish of manadequer is limited to the year and not be able to purchase of a particular use, not will any old scienterior constitute a warranty or amend this specific warrant as to abuse of the fature, improper residently, or repair, or modification of the fature without procedular use. In or will any old scienterior constitute a warranty or amend this specific warrant as to abuse of the fature, improper residently, or repair, or modification of the fature without procedular use. In or will any old scienterior constitute a warranty or amend this specific warrant as to abuse of the fature, improper residently, or repair, or modification of the fature without procedular use. In or will all the procedular use in the procedular use of the fature without procedular users.